

# smartcontroller

Electrical Excellence







**ACCURACY FIXING**

**VOLT METER**



## OPERATION FOR ACCURACY FIXING - VOLT METER

STANDARD VOLT INPUT (V)	OPERATION		EXAMPLE
	Steps	Code for Accuracy Fixing	
100V AC	Power On: Connect Terminal 1 and 2	2032	<p>When the standard volt input is 380V , the code for fixing accuracy is <b>2035</b>. Follow the step  and  to finish entering the code <b>2035</b> and press the button "" to confirm the setting.</p>
220V AC	Long Press " SET " Button for 2 seconds the screen will display " SET ".	2033	
380V AC	Then Press Button " SET " the screen will display " DISP "	2035	
	Then Press Button "  " the screen will display nothing, just black now press "SET" button again into fix accuracy of the meter		
<b>NOTE :</b>	When fixing accuracy of Volt Meter, Please sure the volt input should be standard and stable.		





UNIT C7/4 Inchinnan Industrial Park  
Glasgow, Renfrewshire PA49RJ,  
UNITED KINGDOM



[info@smart-controllers.com](mailto:info@smart-controllers.com)



[www.smart-controllers.com](http://www.smart-controllers.com)

